






Sinergy III Series UPS 700 VA Low Voltage







| Model | ACDEF700-11 |
|-----------------------------------|--|
| Part Number | 17071-01R |
| Туре | Sinergy III |
| Power Rating | 700 VA / 630 W |
| Тороlоду | On-Line Double Conversion |
| Heat Dissipation (BTU/Hour) | 409 at 100% Load |
| Input Voltage (Nominal) Range | 100-120 VAC 90-150 VAC |
| Input Frequency | 50/60 Hz ±4 (Auto Sense on Start-Up) |
| Input Power Factor | >0.95 |
| Input Current THD | <9.0% |
| Efficiency | >84.0% |
| Output Voltage | 120 VAC (Default) 100/110/115 VAC (Selectable) |
| Output Current | 5.8 A (Default) 7.0/6.4/6.1 A (Selectable) |
| Voltage Regulation | ±1.0% |
| Overload Online Mode | 100-105%: Continuous; Warning Only 105-130%: 2 Minutes 130-200%: 10 Seconds >200%: 250 Milliseconds |
| Overload Battery Mode | 100-105%: Continuous; Warning Only 105-130%: 10 Seconds >130%: 250 Milliseconds |
| Overload Bypass Mode | 100-110%: Continuous; Warning Only 110-120%: 30 Minutes 120-130%: 10 Minutes >130%: 1 Minute |
| Battery Voltage (Float / Nominal) | 27.4/24.0 VDC |
| Charger Current | 1.0 A |
| Backup Time (Full Load) | >5.7 Minutes |
| Communications Interface | USB / RS-232 |
| Shipping Weight | 37.0 lbs. / 16.8 kg. |

*



SPECIFICATIONS

Warranty/Support: Sinergy III Series products (hereafter referred to as "Product") are warranted to be free from defects in material and workmanship for two (2) years from date of shipment from POWERVAR, on the chassis & electronic components and two (2) years from date of shipment from POWERVAR on the batteries. This warranty is limited to repairing, replacing, or refurbishing, at POWERVAR's option, any defective component, circuit board or module within the Product. This warranty will include, at POWERVAR's sole discretion, on-site service or POWERVAR depot service. See the Limitations of Warranty section below for additional limitations & exclusions.

Battery Life Disclaimer: POWERVAR's standard battery warranty applies only to UPS and UPM products which are continuously connected to AC mains power, except during utility power outages. Products which are regularly and intentionally disconnected from AC mains power will experience battery discharge/charge cycles potentially far more numerous than those for which the battery was designed. As a result, products used in such applications will experience substantially reduced battery life. For that reason, POWERVAR's standard battery warranty does not apply for applications in which the UPS or UPM product is regularly and intentionally disconnected from AC mains power. POWERVAR UPS and UPM products used in such applications shall receive a 90 day warranty on batteries.

POWERVAR, Inc. - 1450 Lakeside Drive, Waukegan, IL 60085 POWERVAR, Ltd. - Unit 5 Birch, Kembrey Park, Swindon, Wiltshire, UK SN2 8UU